

Koenig Elementary School Facilities Assessment July 2021



Summary of Maintenance Needs

2021 Facility Assessment Summary									
Building System	(1	1 year w/ inflation)		2-5 years w/inflation)		6-10 years (w/ inflation)		Subtotal	
General Building Issues	\$		\$		\$	-	\$	-	
Roofing Issues	\$	13,666	\$	1,182,408	\$	-	\$	1,196,074	
Exterior Issues	\$	-	\$	-	\$	-	\$	-	
Site/Parking Lot Issues	\$	-	\$	-	\$	-	\$	-	
Fire Protection Issues	\$	-	\$	-	\$	-	\$	-	
Plumbing Issues	\$	-	\$	13,621	\$	-	\$	13,621	
Mechanical Issues	\$	12,584	\$	1,386,161	\$	-	\$	1,398,745	
Electrical Issues	\$	-	\$	417,784	\$	-	\$	417,784	
SUM BUILDING	\$	26,250	\$	2,999,974	\$	-	\$	3,026,224	

General Observations:


1. The budgets developed for this report are for the purposes of prioritizing and decision making. Due to the nature of the items observed, the full extent of repair and/or replacement cannot be ascertained without deconstructing spaces in which they were found. Upon prioritization of issues to be resolved, we will investigate fully and provide complete engineered solutions with finalized costs for final review/approval. During inspection spaces were not inspected for Hazardous Materials such as lead paint, asbestos, etc. CG Schmidt, Inc. has made every reasonable effort to review the spaces available to us and to assign budgets that reflect cosmetic solution for the items found.



Koenig Elementary School Facilities Assessment July 2021



Summary of Maintenance Needs





2021 TWO RIVERS PUBLIC SCHOOLS FACILITIES ASSESSMENT 1114 Lowell Street Koenig Elementary School July 2021



		2%		2022		2023-2026	2027-2031		
Item #	Description	Year (w/ 2% inflation)		1 Year		2-5 Years	6-10 Years		
Genera	al Building Replacement or Repairs								
G1 - G83 I	Included in district maintenance plan								
Roof R	Replacement or Repairs								
R1	Two skylights are cracked and need to be replaced	2022	\$	7,550	\$	-	\$ -		
R2	Caulking needed at wall panels	2022	\$	1,711	\$	-	\$ -		
R3	Pillowing at parapet walls.	2022	\$	4,404	\$	-	\$ -		
R4	5 years left on overall roof.	2025	\$	-	\$	1,182,408	\$ -		
Exterior Replacement or Repairs									
X1 - X11 Included in district maintenance plan									
Site Replacement or Repairs									
S1 - S2 Inc	cluded in district maintenance plan								
Fire Pr	otection Replacement or Repairs								
F1 Include	ed in district maintenance plan								
Plumb	ing Replacement or Repairs								
P1	Replace hot water heater	2026	\$	-	\$	13,621	\$ -		
Mecha	anical/HVAC Replacement or Repairs								
M1	Add AC to IT closet	2022	\$	12,584	\$	-	\$ -		
M2	Exhaust system maintenance	2026	\$	-	\$	27,243	\$ -		
M3	Add air conditioning to entire building	2025	\$	-	\$	1,358,918	\$ -		
Electri	cal Replacement or Repairs								
E4	Upgrade incoming electrical power	2026	\$	-	\$	115,782	\$ -		
E5	Upgrade fiber cabling in school	2026	\$	-	\$	74,918	\$ -		
	Cable labeling	2026	\$	-	\$	27,243	\$ -		
E6									



2021 TWO RIVERS PUBLIC SCHOOLS FACILITIES ASSESSMENT 1114 Lowell Street Koenig Elementary School July 2021



Item#	Description	Year (w/ 2% inflation)	1 Year	2-5 Years	6-10 Years
	Koenig Elementary School Total	w/ Inflation:	\$ 26,250	\$ 2,999,974	\$ -

Key

- **G** General Building Issues
- R Roofing Issues
- X Exterior Issues
- S Site Work Issues
- F Fire Protection Issues
- P Plumbing Issues
- M Mechanical Issues
- E Electrical Issues